

Voltage Class	Area	Station Name	Customer Name	Also Known As	MPRN	MIC	MEC	Billing Class	Winter				Summer			
									12:30		18:00		Valley		Peak	
									MW	Var	MW	Var	MW	Var	MW	Var
110 kV	Dublin North	Barnakyle							6.96	0.02	7.15	0.03	6.42	0	8.64	0
110 kV	Dublin North	Corkagh							34.04	7.17	33.25	6.77	31.46	6.48	32.87	6.24
110 kV	Dublin North	Newburry							28.78	4.19	28.32	4.06	25.51	3.73	25.91	3.6
110 kV	Dublin South	Bancroft							22.19	3.08	21.83	2.95	20.84	2.96	22.43	3.22
110 kV	Dublin South	Kilmahud							13.04	0.79	12.8	0.75	9.06	0.46	8.38	0.37
110 kV	Dublin South	Bancroft							9.09	-0.84	9	-0.82				
110 kV	Dublin North	Kilmore							0.97	0.9	0.93	0.85	1.23	1.12	1.52	1.28
110 kV	Dublin North	Grange Castle							7	1.44	6.29	1.2	3.51	0.17	5.37	0.7
110 kV	Dublin North	Dardistown							7.59	0.58	6.31	0.13	8.18	0.87	8.77	1.18
110 kV	Dublin Central	Whitebank							0	0.1	0	0.1	0.1	0.2		
110 kV	Killarney	Glenlara							-0.29	-13.61	-0.59	-13.6	-14.02	-15.6	0	-13.18
110 kV	Ballina	Tawnaghmore							0.04	0.01	0.04	0.01				
110 kV	Letterkenny	Sorne Hill							0.12	0.21	1.7	-0.41	0.15	-0.4	0.24	-0.06
38 kV	Kilkenny	Ballyconra							2.45	0	2.32	0	0.22	0	1.03	0
38 kV	Limerick	Rivers							10.52	3.88	9.19	4	10.74	3.66	8.42	3.32
38 kV	Tralee	Island							3.77	0.82	3.81	0.81	6.98	2.13	7.55	2.33
38 kV	Limerick	Analog							9.08	3.13	9.08	3.25	7.59	2.61	8.83	2.98
38 kV	Limerick	Cloughkeating							2.93	0.44	2.84	0.44	2.23	0.4	2.73	0.43
38 kV	Bandon	Dunderrow							2.71	0.78	2.83	0.69	6.92	1.93	7.03	1.72
38 kV	Fermoy	Flaxfort							5.8	0.45	5.74	0.4	0.17	0.19	5.34	0.01
38 kV	Newcastlewest	Askeaton							0	0	0.41	0	1.42	0	0.01	0
38 kV	Dublin Central	Inchicore							6.84	0.96	6.95	1.04	0.5	0.32	5.98	0.56
38 kV	Athlone	Monksland							3.29	1.29	3.29	1.37	2.78	1.61	3.23	1.07
38 kV	Waterford	Snowhill							5.51	0.85	5.52	0.82	4.58	0.41	2.85	0.91
38 kV	Cork	Barnahely							4.37	1.3	4.26	1.25	3.94	1.24	4.84	1.69
38 kV	Thurles	Holycross Road							6.35	2.69	4.84	1.76	3.85	1.12	6.2	1.82
38 kV	Galway	Ballybrit							1.98	0.83	0.78	0.43	1.6	0.4	3.9	1.11
38 kV	Bandon	Inchinasling							4.63	1.33	3.92	1.06	4.15	1.13	3.5	0.81
38 kV	Clonmel	Lawlesstown							1.78	0.46	1.83	0.47	1.07	0.48	3.31	0.78
38 kV	Dublin South	Cheeverstown							3.09	1.78	0.45	0.03	0.27	0.02	1.61	0.95
38 kV	Clonmel	Redmondstown							2.2	0.75	2.32	0.72	0.97	0.26	2.41	0.81
38 kV	Drogheda	Newtownstalaban							1.67	0.24	1.64	0.21	3.01	0.92	2.65	0.67
38 kV	Waterford	Serpentine Avenue							1.7	0.33	1.78	0.21	1.1	0.14	2.48	0.42
38 kV	Ennis	Clarecastle							1.83	0.68	1.82	0.72	0.86	0.52	2.2	0.85
38 kV	Waterford	Drumdowney							0.14	0.13	0.08	0.06	2.56	0.6	0.15	0.14
38 kV	Arklow	Rathdrum							0.39	0.02	0.4	0.01	1.4	0.48	2.06	0.56
38 kV	Cork	Holly Hill							2.02	0.03	1.88	0.08	0.96	0.01	1.91	0.22
38 kV	Dublin Central	Holyrood Park							0.84	0.06	0.87	0.08	0.01	0.02	0.62	0.04
38 kV	Dublin South	Shankill (dart)							0.78	0.07	0.52	0.05	0.01		0.77	0.07
38 kV	Dublin North	Bayside							0.67	0.1	0.58	0.07	0	0	0.49	0.06
38 kV	Cork	Loughbeg							0.71	0	0.02		0.01		0.86	0.03
38 kV	Dublin Central	Parkview							0.32	0.05	0.36	0.05	0		0.2	0.03
38 kV	Dublin South	Dalkey							0.45	0.09	0.4	0.08	0	0.02	0.25	0.05
38 kV	Thurles	Galmoy							0.07	0.04	0.07	0.03	0.04	0.03	0.07	0.04
38 kV	Dublin South	Harbour							0.37	0.06	0.3	0.04	0		0.23	0.05
38 kV	Dublin Central	Pearse Street							0.27	0.05	0.31	0.06	0	0	0.26	0.05
38 kV	Dublin North	Raheny							0.35	0.07	0.58	0.13	0	0	0.3	0.06

Voltage Class	Area	Station Name	Customer Name	Also Known As	MPRN	MIC	MEC	Billing Class	Winter				Summer			
									12:30		18:00		Valley		Peak	
									MW	Var	MW	Var	MW	Var	MW	Var
38 kV	Waterford	Belview							0.14	0.53	0.23	0.55	0.08	0.06	0.12	0.36
38 kV	Dublin South	Rathdown							0.21	0.02	0.32	0.04	0.08	0	0.41	0.06
38 kV	Dublin North	Portmarnock							0.31	0.06	0.31	0.06	0	0	0.29	0.06
38 kV	NEWBRIDGE	Srah							0.39	0	0.39	0	0.38	0	0.52	0
38 kV	Dublin North	Malahide							0.04	0	0.06	0	0	0	0.04	0
38 kV	Kilkenny	Callan							0.05	0	0.02	0	0.02	0	0.05	0.03
38 kV	Dublin North	Dunsink							0	0	0.02	0	0	0	0	0