

DISTRIBUTION CODE MODIFICATION PROPOSAL FORM

Modification Proposal submitted By: Colm MacManus	DATE OF SUBMISSION OF PROPOSAL: 21 July 2021	Modification Proposal Number: <i>(to be assigned by Review Panel Secretary)</i> #56
CONTACT DETAILS FOR MODIFICATION PROPOSAL ORIGINATOR: (IF NOT DISTRIBUTION CODE REVIEW PANEL		
NAME: Colm MacManus		TELEPHONE NUMBER: 087 3768914
E-MAIL ADDRESS:	colm.macmanus@eirgrid.com	
MODIFICATION PROPOSAL TITLE:	Inclusion of RCES for Topology 4-5	
DISTRIBUTION CODE SECTION(S) AFFECTED BY PROPOSAL DCC11.6.1.2		
MODIFICATION PROPOSAL DESCRIPTION <i>(Clearly state the desired amendment and all text changes. Attach further information if necessary)</i> Add the following text: f) ON/OFF status of TSO remote control enabled switch, which disables the ability of the TSO to send commands to the PPM.		
MODIFICATION PROPOSAL JUSTIFICATION <i>(Clearly state the reason for the modification. Attach further information if necessary)</i> The TSO remote control enabled switch allows telecoms work or testing to be carried out safely. The position indication (PI) of this switch is also relayed back to NCC, which prevents (or identify) issues following work on site. As such, ON/OFF status of this switch has been included in all signals list issued for Controllable PPMs to date. However, due to an oversight, the status of this switch was not included in DCC11.6.1.2 - Signal List #2. The purpose of this mod is to correct that oversight and remove any ambiguity around the need for this signal, as well as aligning with current custom and practice.		
IMPLICATIONS OF NOT IMPLEMENTING THIS MODIFICATION TSO Remote Control Enable Switch will no longer be available to NCC.		
PLEASE SUBMIT MODIFICATION PROPOSALS TO THE PANEL SECRETARY BY E-MAIL TO: DistCodePanel@mail.esb.ie		

