DISTRIBUTION CO	DDE MODIFICATION	PROPOSAL FORM
Modification Proposal submitted By:	DATE OF SUBMISSION OF PROPOSAL:	Modification Proposal Number:(to be assigned by Review Panel Secretary) #57
Tony Hearne	3-12-21	
CONTACT DETAILS FOR MODIFICATION PROPOSAL ORIGINATOR: (IF NOT DISTRIBUTION CODE REVIEW PANEL		
NAME: Tony Hearne		TELEPHONE NUMBER: 087 2238855
E-MAIL ADDRESS:	tony.hearne@esb.ie	
MODIFICATION PROPOSAL TITLE:	Housekeeping and correction of text to reflect the use of a DSO RTU to give effect to Controllability requirements per Mod#36.	
DISTRIBUTION CODE SECTION(S) AFFECTED BY PROPOSAL		
1. DCC11.6 Signal Lists 1-6		
<b>MODIFICATION PROPOSAL DESCRIPTION</b> (Clearly state the desired amendment and all text changes. Attach further information if necessary)		
In each of signal lists 1-6, the text below:		
"shall make the following signals available at the <b>TSO Telecommunications</b> Interface Cabinet located at the <b>PPM</b> site:"		
To be replaced with		
"shall make the following signals available at either the DSO RTU, or the <b>TSO Telecommunications Interface Cabinet</b> located at the <b>PPM</b> site or both, as specified in the signal list provided by TSO or DSO::"		
<b>MODIFICATION PROPOSAL JUSTIFICATION</b> (Clearly state the reason for the modification. Attach further information if necessary)		
As per a Memorandum of Understanding between ESB Networks and EirGrid, the Controllability and other requirements per Mod #36 applicable to PPMs >1MW shall be implemented through the use of a DSO RTU which has the functionality to give effect to these requirements. The existing text is specific to a TSO RTU only and does not reflect the MoU and practice on the ground.		
IMPLICATIONS OF NOT IMPLEMENTING THIS MODIFICATION		
The text concerned contravenes the updated practice, as established in a MoU between the DSO and TSO, as noted at the DCRP meeting on $3^{rd}$ March 2020.		
PLEASE SUBMIT MODIFICATION PROPOSALS TO THE PANEL SECRETARY BY E-MAIL TO: DISTCODEPANEL@MAIL.ESB.IE		

. . .