

- Note:
  - To comfortably facilitate the installation of this unit, builders should provide an • opening of (h)606mm, (w) 403mm, (d) 155mm
  - The meter cabinet must be directly accessible from the main entrance driveway. A • position on the house wall facing the driveway, or within 2m of either corner of this wall is normally acceptable subject to proper access.
  - Each outside box must have identification to associate it with a particular • installation/address, this I.D. should be in place at service installation stage.
  - This is a Guideline and should be used as a reference only. Please refer to Page 1 • of the National Code of Practice for more detailed requirements. This can accessed via the ESB website, <u>www.esb.ie</u>, or via the following link http://www.esb.ie/esbnetworks/downloads/national\_code\_of\_practice.pdf