



03 February 2020
602620 L06 (01):

Bluebell Business Centre
Old Naas Road
Bluebell
Dublin 12
Ireland

Telephone: +353 1 244 4511
www.rskgroup.ie

[REDACTED]

ESB Engineering and Major Projects
One Dublin Airport Central
Dublin Airport
Cloghran
Co. Dublin
Ireland

Recommendations for Potential Further Site Works at Site #29; Unidare – Whitehall

[REDACTED]

RSK submitted a Preliminary Environmental Site Assessment (PSA) report for site# 29 Unidare - Whitehall (Report ref: 602620 R03 dated September 2019). The site is the location of a leakage of cable fluid from a high voltage (HV) underground cable which occurred in early 2010. It is RSKs understanding that the fluid contained Linear Alkyl Benzene (LAB) and that the total fluid loss was approximately 450 litres.

Due to the low risks identified for all potential pollutant linkages, there is no recommendation for an intrusive investigation at the site. However, should any works be planned in the vicinity of the leak location which requires excavation of soils, RSK would recommend assigning an engineer to observe soil and groundwater conditions; and to collect soil and groundwater samples for laboratory analysis.

Yours sincerely

For RSK Company Limited

[REDACTED]

Principal Consultant

